



LAPI LABORATORIO PREVENZIONE INCENDI S.p.A.
 Sede Primaria: I-59100 PRATO - Via della Quercia, 11
 Telefono +39 0574.575.320 - Telefax +39 0574.575.323
 Sede Secondaria: I-50041 CALENZANO (FI) - Via Petrarca, 48
 e-mail: lapi@laboratoriolapi.it
 web site: www.laboratoriolapi.it

Notified Body N°0987
 Directive 89/106 CEE



EC - Certificate of Conformity 0987-cpd-94 rev.1

in compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of law, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product :

building product of the family:

STEPWAY/ STUDWAY B

Denominated

BK SV, TM-BK GT, TP-BK GT, TM-BB

Description of the product:

Resilient floor covering , thickness from 2.7 to 4.0 mm, various colours

Type: **Resilient rubber floor covering, surface: studded**

Use: **Floor covering**

End uses: **Laid with or without adhesive to non combustible support belonging to Euroclass A1_{fl} or A2_{fl}**

Commercialized:

REMP S.p.a.

Via dell'Industria, 11 - 48010 FOGNANO (RA) - ITALY

is submitted by the manufacturer to factory production control (FPC) and testing of samples (ITT) by the Notified body for Certification, Inspection and Testing according to Directive 89/106 CEE.

The notified body (**LAPI SpA - Laboratorio Prevenzione Incendi N° 0987**) has performed the initial type testing on the samples taken at the factory in accordance with the described test for the relevant characteristics of the product, the initial inspection of the factory and the factory production control and it will perform the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the Attestation of Conformity System AoC 1 and the performances described in Annex ZA of the standard

EN 14041: 2004 - EN 14041: 2004/AC (2006)

Resilient, textile and laminate floor coverings - Essential characteristics

are performed and the product complies with characteristics required as for:

Formaldehyde emission: class E1*

Slip resistance EN 13893: 2005: Class DS


Moreover the product has reaction-to-fire Euroclass classified according to EN 13501-1:2009 standard and evaluated according to Annex D.8 Table D.1 of the product standard EN 14041: 2004 - EN 14041: 2004/AC

(*): Absent.

This result is valid in the following conditions:

Laid with or without adhesive to non combustible support belonging to Euroclass A1_{fl} or A2_{fl}

B_{fl} - s1



This renewal of the certificate issued for the first time on 12/07/2007 and revised on 31/08/2011, was released on 10/07/2012 without repetition of tests and it remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or as long as the factory production control itself are not modified significantly and latest until 09/07/2017

Prato, 10/07/2012

The Technical Director
 Dr. Luca Ermini