

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

TOLI Corporation

2-10-4 Higashi-Shinbashi, Minatoku, Tokyo, Japan

For the following product(s):

Sheet Vinyl:

ARENA FIT, BATHNA FLORE, BATHNA REALDESIGN, CARE SAFE NW, CF SHEET SERIES, CHEMICAL-RESISTANT SUPER K SHEET(SERIES), DEODORANT NS TOWARE NW, EARTHLEUM, HOSPILEUM NW, LAVANA, NEW CLINESS SHEET (CUSHION), NEW STANLOAD, NONWAXLEUM (SERIES), NS 4400 AQUA TREAD, NS9500 NEW TOUGHSHINE, NS FLATY, NS REAL DESIGN, NS STEP 800 (STEPS), OPELEUM, SF FLOOR NW

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m^3 (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-03029

Valid from: April 1, 2020 to March 31, 2021

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ISO/IEC 17065
Product Certification Body
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA
www.scsglobalservices.com